CVE-2025-9063

Authentication Bypass in PanelView Plus 7 Web Browser ActiveX

High severity. Unauthorized access to file system, diagnostics and logs. Fixed in V14.103 firmware.

CVE-2025-9064

Path Traversal in FactoryTalk View ME / PanelView Plus 7

High severity. Unauthenticated deletion of files on the panel OS. Fixed in V14.103 firmware.

CVE-2024-21914

Remote Restart Security Protection Issue

Medium severity. Remote restart can cause loss of HMI view/control. Corrected in later FactoryTalk View ME versions.